



FIGURE D-18.—Launch complex 39D with vehicle 500 F in place.

Over the past year, we have had some troubles, and here is an event which I thought would be of interest to you. Figure D-19 is the liquid oxygen storage tank at pad A. This drawing (fig. D-20) will be used to illustrate the operations of this facility and the problem that occurred. The lox tank is a large tank, as you can see. The outlet pipe is located as shown in the figure. It has an outlet out to the pads, through the T joint and by the redundant lines.

These two pumps, each capable of 10,000 gallons flow per minute, serve the two outlet lines. From the T the line goes in this direction through a manual valve, through an automatic valve, which could be actuated remotely, then through the pump and up to the pad.

At the time the accident occurred, this particular line (fig. D-21) was being used. What happened was that suddenly this pipe broke as shown. An analysis showed the following series of events to have occurred: (1) The manual valve was opened and then the automatic valve started to open by remote control; (2) as the second valve started to open, gas against the face of the valve came through very quickly; (3) suddenly the gas was followed by a wall of liquid oxygen which impinged on the valve element opening against the flow of liquid, and the forces were such that it broke the pipe; and (4) the section at the flexible connection broke, as you can see.

A point that I would like to make is that the operation just described is, in fact, an R. & D. effort. The flow of liquid oxygen through this pipe is 10,000 gallons a minute. Nobody has done that before. We