

8. Paragraph 2. *Applicable documents.*—The current edition designation of all documents shall be inserted in this paragraph. The current issue of NavDocks "Index of Specifications Used in Contracts for Public Works," "Department of Defense Index of Specifications and Standards," and industry document indexes should be consulted. When an interim or uncoordinated Federal or military specification is referenced, the proper designation therefor should be included; for example, SS-S-00200 (GSA-FSS), MIL-C-18480 (DOCKS). The current amendment, addenda, or errata number for yards and docks, Federal, and military specifications shall be inserted immediately following the specification or current edition designation; for example, MIL-B-7883A(1). It is not necessary to include addresses where documents may be obtained; however, it may be desirable to do so for documents which are not well known.
9. Paragraph 3.3.2. *Concrete subfloors.*—Specify in the "Concrete Construction" section of the specification, vapor barriers and gravel fill under subfloor on grade; dusted on finish on subfloors; prohibition of the use of curing compounds, hardeners, sealers, or any other substance which would interfere with the bonding of the adhesive.
10. Paragraph 3.3.3. *Wood subfloors.*—Specify underlayment over wood subfloors in the "Carpentry" and "Woodwork" section of the specification; specify both underlayment and felt over wood subfloors.
11. Paragraph 3.3.5. *Moisture test, et cetera.*—A meter suitable for this test is the relative humidity indicator which may be obtained from Abbeon Supply Co., 179-45K Jamaica Avenue, Jamaica, N.Y.
12. Paragraph 3.4.1. *Application of floor coverings.*—Indicate edging and thresholds on project drawings; specify thresholds in "Hardware" section of the project specification.
13. Paragraph 3.4.4. *Application of linoleum or vinyl plastic roll flooring.*—Specify locations where waterproof seams are desired; specify waterproof seams only in areas subject to abnormal surface moisture.
14. Paragraph 3.4.5. *Application of rubber or vinyl core base.*—When cove base is to be applied to plaster walls, specify in the "Plastering" section of the specification that the final coat of plaster shall extend to, and be finished square with the floor.
- 3.6. *Protection.*—Cleaned flooring shall be covered with clean building paper before traffic is permitted. Board or plywood walkways shall be placed on floors used as passageways by workmen, and where directed.
4. *Quality assurance provisions.*—
- 4.1. *Samples.*—Duplicate sets of the manufacturer's standard color chips, not less than 3 by 3 inches, showing typical color, finish, and surface pattern of each type of floor covering, shall be submitted for color selection prior to the submission of samples. The following samples of floor covering materials in the colors selected shall be submitted for approval before the work is started:
- a. Field tiles, three of each type.
 - b. Borders, three 9-inch lengths of each type.
 - c. Sheet coverings, two 12- by 12-inch pieces of each type.

